

A = 125mm: Outer Diameter HDPE ESB Approved Duct, SDR=17.6 (Power) [ESB Code: 9317552]
 B = 125mm: Outer Diameter HDPE ESB Approved Duct, SDR=17.6 (Comms) [ESB Code: 9317552]



Note:

- This drawing is subject to ESB design approval and should not be used for construction.
- This drawing is to be read in conjunction with relevant drawings, specifications and reports
- Dimensions are in millimeters, unless noted otherwise
- Drawings are not to be scaled use figured dimensions only

ALL REINSTATEMENT WORKS ARE TO BE IN ACCORDANCE WITH LANDOWNER REQUIREMENTS

Reinstatement details based on Guidelines for Managing Openings in Public Roads - SD14

Typical Section Through Access Track
SCALE 1:10

 <p>Head Office Beenreigh, Abbeydorney, Tralee, Co. Kerry Ireland Tel: 00353 66 7135710</p>	<p>CLIENT</p> 	<p>PROJECT</p> <p>Dyrick Hill Wind Farm</p> <p>110kV Grid Connection</p>	<p>SHEET TITLE</p> <p>110kV Ducting Through Access Track</p>	<p>ISSUE/REVISION</p>								
		<p>PROJECT NUMBER</p> <p>05-829</p>	<p>SHEET NUMBER</p> <p>05829-DR-151</p>	<p>DRAWING STATUS</p> <p>For Planning</p>	<table border="1"> <tr> <td></td> <td></td> <td></td> </tr> <tr> <td>P0</td> <td>16.09.22</td> <td>Issued For Planning</td> </tr> <tr> <td>I/R</td> <td>DATE</td> <td>DESCRIPTION</td> </tr> </table>				P0	16.09.22	Issued For Planning	I/R
P0	16.09.22	Issued For Planning										
I/R	DATE	DESCRIPTION										